



United States Department of Agriculture  
Animal and Plant Health Inspection Service  
Teachable Moments

Legal Name: COVANCE LABORATORIES INC

Customer Number: 640 Certificate Number: 35-R-0030

Inspection Date: 24-FEB-20 Site Number: 011

Inspector: KATHARINE FRANK, D V M

Section: \_\_\_\_\_

**3.2(d) INDOOR HOUSING FACILITIES.**

Concrete block walls within the primary enclosure need to be sealed and impervious to moisture.