



Inspection Report

BIOQUAL INC
9600 MEDICAL CENTER DRIVE
Suite 101
ROCKVILLE, MD 20850

Customer ID: **93**
Certificate: **51-R-0036**
Site: 003
BIOQUAL INC

Type: ROUTINE INSPECTION
Date: 06-AUG-2021

3.75(c)(2)

Housing facilities, general.

The floors in the animal rooms (the older part of the facility) are pitted and stained floors. The condition of the floors are past normal wear and tear and can no longer be adequately cleaned and sanitized. The floors have not been maintained at a frequency that facilitates good husbandry practices. The floors must be replaced for effective cleaning and sanitization and a proper gradient that will allow water to flow towards the drains. established. Worn floors must be replaced when it cannot be readily cleaned and sanitized. Correct by following a schedule for replacement and developing a plan to ensure proper maintenance of the floors on a regular basis. Correct by March 31, 2022.

This inspection and exit interview were conducted with the facility representatives. The protocol review was conducted under site 001.

Prepared By: GLORIA MCFADDEN
USDA, APHIS, Animal Care
Title: VETERINARY MEDICAL
OFFICER

Date:
09-SEP-2021

Received by Title: Institutional Officer

Date:
09-SEP-2021



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
93	51-R-0036	003	BIOQUAL INC	06-AUG-2021

Count	Scientific Name	Common Name
000126	<i>Macaca fascicularis</i>	CRAB-EATING MACAQUE / CYNOMOLGUS MONKEY
000710	<i>Macaca mulatta</i>	RHESUS MACAQUE
000002	<i>Macaca nemestrina</i>	PIG-TAILED MACAQUE
000838	Total	