



## Inspection Report

---

NEW YORK STATE PSYCHIATRIC INSTITUTE  
1051 RIVERSIDE DRIVE  
NEW YORK, NY 10032

Customer ID: **325904**

Certificate: **21-R-0223**

Site: 001

NEW YORK STATE  
PSYCHIATRIC INSTITUTE

Type: ROUTINE INSPECTION

Date: 26-MAY-2022

---

### 3.84(c)

#### Cleaning, sanitization, housekeeping, and pest control.

Cagewash rooms had extensive sections of peeling paint, exposed seams, and damaged drywall, which was present on almost every section of the dirty side ceiling surface, including an approximately 2x1 inch hole completely through the drywall in that room. Damaged surfaces in cagewash areas impair proper sanitary practices and may contribute to contamination of animal cages and water bottles. Rooms used to facilitate required husbandry practices must be kept in good repair.

Dirty side ceiling to be repaired by 26 July 2022.

This inspection and exit interview were conducted with the facility representative.

Additional Inspectors:

Lemnique Wafer, Assistant Director

---

**Prepared By:** SARA TOBIAS

USDA, APHIS, Animal Care

**Date:**  
26-MAY-2022

**Title:** VETERINARY MEDICAL  
OFFICER

**Received by Title:** Facility Representative

**Date:**  
26-MAY-2022



### Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
325904	21-R-0223	001	NEW YORK STATE PSYCHIATRIC INSTITUTE	26-MAY-2022

Count	Scientific Name	Common Name
000015	<i>Macaca mulatta</i>	RHESUS MACAQUE
000015	<b>Total</b>	