

# **VIII. Membership of the IACUC**

Date: 5/17/19			
Name of Institution: Nathan S. Kline Institute for Psychiatric Research			
Assurance Number: A4545-01			
<b>IACUC Chairperson</b>			
Name*: Henry Sershen			
Title*: Research Scientist, Neurochemistry		Degree/Credentials*: PhD	
Address*: (street, city, state, zip code) Nathan S. Kline Institute for Psychiatric Research Building 35, 140 Old Orangeburg Road Orangeburg, New York 10962			
E-mail*: sershen@nki.rfmh.org			
Phone*: (b) (6)		Fax*: (b) (6)	
<b>IACUC Roster</b>			
Name of Member/ Code**	Degree/ Credentials	Position Title***	PHS Policy Membership Requirements****
Mark M. Klinger	BS, DVM, DACLAM	Lab Animal Resource Director	Veterinarian
(b) (6)			Scientist
			Scientist
			Scientist
			Scientist
			Scientist
			Scientist
			Scientist
			Non-Affiliated, Non-Scientist
			Non-Scientist, alternate

**X. Facility and Species Inventory**

Date: 5/17/19			
Name of Institution: Nathan S. Kline Institute for Psychiatric Research			
Assurance Number: A4545-01			
Laboratory, Unit, or Building*	Gross Square Feet [include service areas]	Species Housed [use common names, e.g., mouse, rat, rhesus, baboon, zebrafish, African clawed frog]	Approximate Average Daily Inventory
(b) (4)	4,332 **	Mice	17,916
	756	Rats	430
	901	Rhesus monkeys, capuchin monkeys,	24
	362	n/a	
	1,080	n/a	
	755	n/a	
	298	n/a	
	176		
	170	n/a	
	4,040	n/a	
<b>Total#</b>	<b>13, 800</b> Gross sq. ft.		

\*Institutions may identify animal areas (buildings/rooms) by a number or symbol in this submission to OLAW. However, the name and location must be provided to OLAW upon request.

## I. Semiannual Program Review and Facility Inspection Report

**Date:** 12/18/18

**Members in Attendance:** H. Seršen, M. Klinger (DVM),

(b) (6)

(b) (6)

(b) (6)

Deficiency Category*	✓	Location	Deficiency and Plan for Correction	Responsible Party	Correction Schedule and Interim Status	Date Completed
M	✓	(b) (4)	(From 12/19/17 Review): "The floor in this section of the corridor is currently acceptable, but is worn and in need of eventual resurfacing. Along with other rooms and corridors a schedule for resurfacing this section of corridor with conventional animal-facility multilayered epoxy with integral coving has been established."	NKI Administration	Extended from 12/31/18 to: 12/31/19  <b>See P. 10. Note for details</b>	Pending
M	✓		Failure of tunnel washer to reach sanitation temperature.	NKI Administration	06/10/19  <b>See P. 13. Note #1 for details</b>	Pending
M			Insufficient capacity to exhaust steam in section of cage-wash suite that houses the tunnel and pass-through box washers.	NKI Administration	06/10/19  <b>See P. 13, Note #2 for details</b>	Pending

\* A = acceptable

M = minor deficiency

S = significant deficiency (is or may be a threat to animal health or safety)

C = change in program (PHS Policy [IV.A.1.a-i.](#)) (include in semiannual report to IO and in annual report to OLAW)

NA = not applicable

✓ Check if repeat deficiency