



United States Department of Agriculture
Animal and Plant Health Inspection Service

SBRUNKHORST
INS-0000851415

Inspection Report

NEOTECH L L C
10061 HWY 22
DRESDEN, TN 38225

Customer ID: 17184
Certificate: 63-R-0116
Site: 001
NEOTECH LLC

Type: ROUTINE INSPECTION
Date: 09-MAR-2023

3.131(c)

Sanitation.

The HVAC air filter and grill in the ferret building are in need of cleaning. The filter itself is all dark grey with dirt except for the very edges which are still the usual white. The grill covering the filter is dirty and sticky with dust and hairs adhered to it. Dirty air filters can lead to unclean air and overwork the HVAC unit such that it no longer works efficiently. The facility shall ensure that the HVAC filter and grill are kept clean in order to protect the animals. Correct by March 17, 2023.

This inspection and exit interview were conducted with the facility/IACUC representative.

Prepared By: SUSANNE BRUNKHORST
USDA, APHIS, Animal Care
Title: VETERINARY MEDICAL
OFFICER

Date:
09-MAR-2023

Received by Title: IACUC Representative

Date:
09-MAR-2023



United States Department of Agriculture
Animal and Plant Health Inspection Service

Customer: 17184
Inspection Date: 09-Mar-2023

Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
17184	63-R-0116	001	NEOTECH LLC	09-MAR-2023

Count	Scientific Name	Common Name
000004	<i>Canis lupus familiaris</i>	DOG ADULT
000002	<i>Mustela putorius furo</i>	DOMESTIC FERRET
000006	Total	