



Inspection Report

Yakima Valley College
P.O. Box 22520
Yakima, WA 98907

Customer ID: 1722

Certificate: 91-R-0051

Site: 001

YAKIMA VALLEY COLLEGE

Type: ROUTINE INSPECTION

Date: 08-MAY-2019

3.1(c)(2)

HOUSING FACILITIES, GENERAL.

The resinous flooring in the facility was redone last summer; however, the top coat of the flooring is already lifting, especially in high traffic areas. The flooring surface has chips and pitting present to include areas inside the kennels for the dogs. The rough and pitted areas of the flooring cannot be readily cleaned and sanitized, and could play a significant role in disease transmission. The flooring must be repaired and maintained to facilitate proper cleaning and sanitation of the facility.

To be corrected by: September 15, 2019

This inspection and exit briefing were conducted with the facility representative.

Prepared By:

FORBES DIANE, D V M

FORBES DIANE, D V M USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL OFFICER 5053

Date:

10-MAY-2019

Received By:

Title:

Date:

10-MAY-2019



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
1722	91-R-0051	001	YAKIMA VALLEY COLLEGE	08-MAY-19

Count	Scientific Name	Common Name
000005	<i>Canis lupus familiaris</i>	DOG ADULT
000004	<i>Felis silvestris catus</i>	CAT ADULT
000009	Total	