



## Inspection Report

Oklahoma State Univ.Ctr For Health Sciences  
1111 West 17th St.  
Tulsa, OK 74107

Customer ID: **335360**

Certificate: **73-R-0119**

Site: 001

Oklahoma State University Ctr for Health Sciences

Type: ROUTINE INSPECTION

Date: 08-DEC-2016

### 3.131(c)

#### SANITATION.

In all three vole rooms, there was an accumulation of dirt/dust/debris on large centrally located ceiling ducts. Since the voles are housed with wire mesh top cages, they are potentially exposed to contamination from the dirt/dust/debris on the ceiling or in the air. Facility needs to clean and maintain the ceiling vents as needed to prevent dirt/dust/debris accumulation.

Correction Date: 12/10/2016 December 10, 2016

This inspection and exit interview were conducted with facility representative.

Additional inspector: Dr. Autumn Unck (VMO)

Prepared By:

**MICHAEL TYGART, D V M**

MICHAEL TYGART USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL OFFICER, 6009

Received By:

**(b)(6), (b)(7)(c)**

Title: REPORT SENT VIA EMAIL

Date:

09-DEC-2016

Date:

09-DEC-2016