



## Inspection Report

Antibodies Inc.  
P. O. Box 1560  
Davis, CA 95617

Customer ID: **7854**  
Certificate: **93-R-0158**  
Site: 001

ANTIBODIES, INC.

Type: **FOCUSED INSPECTION**  
Date: **05-MAR-2019**

### 3.51(d)

#### FACILITIES, INDOOR.

This inspection was focused on the rabbit barn only.

In the rabbit barn, there were two areas that were no longer substantially impervious to moisture or readily sanitized. On the floor of the aisle between the male rabbits the surface of the floor had flaked off, exposing porous concrete. This area of floor was approximately two feet by two feet in size, spanning more than half the aisle that can no longer be readily sanitized. Above the rabbit enclosures, the vent for the swamp cooler had rusted edges and fur caked on the edges. The rusted areas can no longer be readily sanitized. A system of maintenance must be in place to ensure all interior surfaces are maintained in accordance with the regulations to ensure the health and well being of the animals.

Correction Date: 31 May 19

This inspection and exit interview were conducted with facility representatives.

Prepared By: **FRANK KATHARINE, D V M**

FRANK KATHARINE, D V M USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL OFFICER 6091

Date:  
08-MAR-2019

Received By:

Title:

Date:  
08-MAR-2019



## Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
7854	93-R-0158	001	ANTIBODIES, INC.	05-MAR-19

Count	Scientific Name	Common Name
000044	<i>Oryctolagus cuniculus</i>	DOMESTIC RABBIT / EUROPEAN RABBIT
<b>000044</b>	<b>Total</b>	